



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵件
e-mail wsdinfo@wsd.gov.hk

電話
Telephone 2829 4355

圖文傳真
Facsimile 2824 0578

檔號
Reference (3) in WSD 3321/18 Pt.1 T/J(15)

30 January 2018

Approval of "F.Q.R." Angle Valve

Your letter ref. SL20180102 dated 2 January 2018 refers.

Having considered the test report ref. 175041ST171010 issued on 27 December 2017 by Fugro Technical Services Limited, this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: FQR Frattini SRL

Country of Origin: Italy

Brand: F.Q.R.

Details of Fitting: 1/2" x 3/8" x 3/8" Copper alloy angle valve

Model: 258SD

Body Markings: Made in Italy

Expiry Date: 9 November 2022

This Authority hereby permits the use of the above fitting in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fail to meet that of the approved sample or if the fitting is found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fitting in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.


Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 2294 2656.

Yours faithfully,

A handwritten signature in black ink, appearing to be 'Chan Chung Kun', written in a cursive style.

(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



258SD