



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵件
e-mail wsdinfo@wsd.gov.hk

圖文傳真
Facsimile 2824 0578

檔號
Reference (12) in WSD 3321/17 Pt.1 T/J(939)

12 March 2018

Approval of "MR" Ductile Iron Fittings

Your letter ref. DI.170704 dated 4 July 2017 and subsequent submission received by this department on 1 March 2018 refer.

Having considered the test report ref. PMA72575 issued on 8 June 2017 by ETS-Testconsult Limited and WRAS certificate, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Yingkou Ever Foundry Co Ltd

Country of Origin: China

Brand: MR

Details of Fittings: Ductile iron fittings with epoxy powder coating under WRAS approval no. 1701509

Description	Size (mm)
Double Flanged 90° Bend	80, 100, 150, 200, 250, 300
Double Flanged 45° Bend	80, 100, 150, 200, 250, 300
Double Flanged 22.5° Bend	80, 100, 150, 200, 250, 300

Description	Size (mm)
Double Flanged 11.25° Bend	80, 100, 150, 200, 250, 300
Double Socket 90° Bend	80, 100, 150, 200, 250, 300
Double Socket 45° Bend	80, 100, 150, 200, 250, 300
Double Socket 22.5° Bend	80, 100, 150, 200, 250, 300
Double Socket 11.25° Bend	80, 100, 150, 200, 250, 300

Body Markings: For Double Flanged Bend:
MR BSEN545 PN16 K12 DI size x angle

For Double Socket Bend:
MR BSEN545 K12 DI size x angle

Expiry Date: 31 January 2022

This Authority hereby permits the use of the above fittings in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



Double flanged 90° Bend



Double flanged 45° Bend



Double flanged 22.5° Bend



Double flanged 11.25° Bend



Double Socket 90° Bend



Double Socket 45° Bend



Double Socket 22.5° Bend



Double Socket 11.25° Bend