



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓

Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵件

e-mail

wsdinfo@wsd.gov.hk

圖文傳真

Facsimile

2824 0578

檔號

Reference

(2) in WSD 3321/18 Pt.1 T/J(244)

23 March 2018

Approval of "AQUA" Check Valves

Your letter ref. WSD/AP-20022018-1 dated 20 February 2018 refers.

Brand	Model No. (Size)	Fugro Test Report Ref.	Issuance Date
Aqua	FIG.501G (50mm)	174824ST170965	25 Jan 2018
Aqua	FIG.501G (65mm)	174824ST170965(1)	25 Jan 2018
Aqua	FIG.501G (80mm)	174824ST170965(2)	25 Jan 2018
Aqua	FIG.501G (100mm)	174824ST170965(3)	25 Jan 2018
Aqua	FIG.501G (150mm)	174824ST170965(4)	25 Jan 2018
Aqua	FIG.501G (200mm)	174824ST170965(5)	25 Jan 2018

Having considered the above test reports issued by the Fugro Technical Services Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Aqua Valve Co Ltd

Country of Origin: China

Brand: Aqua

Details of Fittings: Ductile iron swing check valve
Model: FIG.501G
Size: 50mm, 65mm, 80mm, 100mm, 150mm, 200mm
Body Markings: ➡ size in inch size in DN
Expiry Date: 30 November 2022

Proviso: The fittings can only be used in non-potable water plumbing system.

This Authority hereby permits the use of the above fittings in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,


(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only




FIG.501G