



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵件
e-mail wsdinfo@wsd.gov.hk

圖文傳真
Facsimile 2824 0578

檔號
Reference (4) in WSD 3321/18 Pt.1 T/J(45)

12 April 2018

Approval of “MICO” Check Valves

Your letters ref. AWSD0001/18 and AWSD0001/18(1) dated 10 January 2018 and 29 March 2018 respectively refer.

Having considered the test report ref. PMA75466 issued on 17 November 2017 by ETS-Testconsult Ltd., this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer:	Henry Engineering & Supplies
Country of Origin:	China
Brand:	Mico
Details of Fittings:	Cast iron wafer type silent check valve
Model and Size:	MI050 – 50mm MI065 – 65mm MI200 – 200mm

Body Markings: *MICO* size in inch - 150

Expiry Date: 20 June 2022

Proviso: The fittings can only be used in fresh water fire services systems.

This Authority hereby permits the use of the above fittings in fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water fire services systems.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



MI050 / MI065 / MI200