



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵件
e-mail wsdinfo@wsd.gov.hk

圖文傳真
Facsimile 2824 0578

檔號
Reference (2) in WSD 3321/18 Pt.1 T/J(285)

12 April 2018

Approval of "SEAH" Black Steel Pipe

Your letter dated 14 March 2018 refers.

Having considered the test report ref. BC-SUMMARY-2017-93 issued on 25 July 2017 by Castco Testing Centre Limited, this Authority accepts that the pipe described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: SeAH Steel Corp

Country of Origin: Korea

Brand: SeAH

Details of Pipe: 250mm Black steel pipe

Body Marking: SeAH Steel EW EN10217-1:2002 P265TR1 C2
(Size) x (Thickness) x (Length) MADE IN KOREA
KHK (Production Code)

Expiry Date: 28 June 2022

Proviso: The pipe can only be used in fresh water fire service systems.

This Authority hereby permits the use of the above pipe in fresh water fire service systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipe to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipe installed fails to meet that of the approved sample or if the pipe is found to be unsuitable for use in fresh water fire service systems.

For the use of the pipe in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the pipe by this Authority.

Should you have any enquiries, please contact our Engineer Mr Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only