



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵件
e-mail wsdinfo@wsd.gov.hk

圖文傳真
Facsimile 2824 0578

檔號
Reference (4) in WSD 3321/18 Pt.1 T/J(245)

26 April 2018

Approval of "TOZEN" Strainer

Your letters ref. TLL/M788/18 dated 26 February 2018 and ref. TLL/M791/18 dated 6 April 2018 refer.

Having considered the test report ref. BC-SUMMARY-2018-9 issued on 9 January 2018 by Castco Testing Centre Ltd. and WRAS certificate, this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer:	Tozen Corporation
Country of Origin:	China
Brand:	Tozen
Details of Fittings:	Ductile iron basket strainer (with epoxy coating under WRAS approval no. 1701509)
Model:	CBS
Size:	450mm
Body Markings:	TOZEN DNXX DI PN16 ←

Expiry Date:

31 January 2022

This Authority hereby permits the use of the above fitting in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fail to meet that of the approved sample or if the fitting is found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fitting in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



CBS