



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵件
e-mail wsdinfo@wsd.gov.hk

圖文傳真
Facsimile 2824 0578

檔號
Reference (4) in WSD 3321/18 Pt.1 T/J(256)

26 April 2018

Approval of "TOZEN" Settlement Joints

Your letters ref. TLL/M789/18 and TLL/M793/18 dated 5 March 2018 and 10 April 2018 respectively refer.

Brand	Model No. (Size)	Nutek Test Report Ref.	Issuance Date
Tozen	LS Connector (50mm)	J22604A	28 Feb 2018
Tozen	LS Connector (80mm)	J22604B	31 Jan 2018

Having considered the above test reports issued by Nutek Systems (HK) Limited and test report ref. EN0161202-24 issued on 24 February 2017 by Castco Testing Centre Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Tozen Corporation

Country of Origin: Thailand

Brand: Tozen

Details of Fittings: Rubber settlement joint

Model: LS Connector

Size: 50mm, 80mm

Body Markings: LS CONNECTOR T0403 TOZEN

Expiry Date: 23 January 2022

This Authority hereby permits the use of the above fittings in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



LS Connector