



水務署

Water Supplies Department

香港灣仔告士打道七號入境事務大樓
Immigration Tower, 7 Gloucester Road, Hong Kong

電子郵件
e-mail wsdinfo@wsd.gov.hk

圖文傳真
Facsimile 2824 0578

檔號
Reference (4) in WSD 3321/18 Pt.1 T/J(441)

7 June 2018

Approval of "ROCA" Mechanical Mixers

Your letters ref. RSL-HK-2018-LTR006 and RSL-HK-2018-LTR006R1 dated 27 April 2018 and 15 May 2018 respectively refer.

Brand	Model No.	Nutek Test Report Ref.	Issuance Date
Roca	5A8360C0G	J22821A	18 Apr 2018
Roca	5A3K09C0G	J22823A	18 Apr 2018

Having considered the above test reports issued by the Nutek Systems (HK) Ltd., this Authority accepts that the fittings described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Roca Sanitario SA

Country of Origin: Spain

Brand: Roca

Details of Fittings: 1. 3/8" Single lever sink mixer
Model: 5A8360C0G

2. 3/8" Single lever basin mixer
Model: 5A3K09C0G

Body Markings:

Roca

Expiry Date:

30 March 2023

This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"The cold water supply to the fittings shall be drawn from the same source that supplies the hot water apparatus so as to provide a balanced pressure and to obviate the risk of scalding in the event of a restriction or failure in the water supply."

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fittings, unless other specified.

For the use of the fittings in any project, the Acceptance Reference Number at the bottom of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(CHAN Chung Kun)
for Water Authority

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



5A8360C0G



5A3K09C0G