



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/18 Pt.1 T/J(539)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

25 June 2018

**Approval of "TOGA" Galvanized Steel Pipe
(General Acceptance No. C20180341FS)**

Your letters dated 24 May 2018 and 31 May 2018 refer.

Having considered the test report ref. PMA82313 issued on 11 May 2018 by ETS-Testconsult Ltd., this Authority accepts that the pipe described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Jinan Mech Piping Technology Co Ltd
Country of Origin: China
Brand: Toga
Details of Pipe: 150mm Galvanized steel pipe (class heavy)
Body Markings: TOGA BSEN10255 CLASS HEAVY
DN150 x 5.4 W
Expiry Date: 6 May 2023

Proviso: The pipe can only be used in fresh water fire service plumbing systems.

This Authority hereby permits the use of the above pipe in fresh water fire service plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipe to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipe installed fails to meet that of the approved sample or if the pipe is found to be unsuitable for use in fresh water fire service plumbing systems.

For the use of the pipe in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipe by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only