



總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/18 Pt.1 T/J(538)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

27 June 2018

Approval of "PM" Copper Fittings (General Acceptance No. C20180355)

Your letters ref. PMB-WSD-180523.2 and PMB-WSD-180523.2.1 dated 23 May 2018 and 8 June 2018 respectively refer.

Having considered the test reports ref. J22895r1, J22896r1 and J22119 issued on 5 June 2018 and 22 November 2017 by Nutek Systems (HK) Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Ningbo Hengsheng Pipe Fitting Co Ltd

Country of Origin: China

Brand: PM

Details of Fittings: Copper fittings with solder ring connection ends

Description	Model	Size
Male Adaptor	SR5401	15mm x 1/2", 28mm x 1"

Body Markings: <PM> EN1254-1 size

Expiry Date: 15 November 2022

This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed should be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



Male Adaptor