



總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (8) in WSD 3321/18 Pt.1 T/J(602)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

12 July 2018

Approval of "CROWN" UPVC Pipes (General Acceptance No. C20180395)

Your letter ref. uPVC/PP/AL/05018002 dated 1 June 2018 and subsequent submission received by this department on 21 June 2018 refer.

Having considered the test report ref. 181067EN181160 issued on 30 May 2018 by Fugro Technical Services Limited, this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Nam Sok Building Materials & Plastic Products (Shenzhen) Co Ltd

Country of Origin: China

Brand: Crown

Details of Pipes: uPVC Pipes in white colour (Class E)

Model	Size
A0A15PP20015000	15mm
A0A15PP20020000	20mm
A0A15PP20025000	25mm
A0A15PP20032000	32mm

Model	Size
A0A15PP20040000	40mm
A0A15PP20050000	50mm
A0A15PP20065000	65mm
A0A15PP20080000	80mm
A0A15PP20100000	100mm
A0A15PP20150000	150mm

Body Markings:

PCV-U model BS 3505 CLASS E
size in mm size in inch production number

Expiry Date:

23 May 2023

Proviso: The pipes can only be used in non-potable water plumbing system.

This Authority hereby permits the use of the above pipes in fresh water plumbing systems and flushing water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fails to meet that of the approved samples or if the pipes are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,

(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only