



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (6) in WSD 3321/18 Pt.1 T/J(617)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

27 July 2018

**Approval of “HKS” Stainless Steel Pipes
(General Acceptance No. C20180456)**

Your letters ref. L18-0516, L18-0602 and L18-0607 dated 31 May 2018, 13 June 2018 and 27 June 2018 respectively refer.

Having considered the test report ref. 174921EN180922C issued on 13 June 2018 by Fugro Technical Services Limited, this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: HK Steel Ltd

Country of Origin: Taiwan

Brand: HKS

Details of Pipes: Stainless steel pipe (316L)

Model and Size:

BS152658-6	- 15mm
BS202658-6	- 20mm
BS253258-6	- 25mm
BS323258-6	- 32mm
BS403258-6	- 40mm
BS503658-6	- 50mm

BS653658-6 - 65mm
BS804058-6 - 80mm
BS1004558-6 - 100mm

Body Markings: HKS BS 6362 AISI 316L size x thickness x length
HEAT NO. (XXX) TW

Expiry Date: 26 April 2023

This Authority hereby permits the use of the above pipes in fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed should be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fails to meet that of the approved samples or if the pipes are found to be unsuitable for use in fresh water plumbing systems.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only