



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (8) in WSD 3321/18 Pt.1 T/J(485)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

8 August 2018

**Approval of “深塑” PE Pipes and Fittings
(General Acceptance No. C20180505)**

Your letter dated 8 May 2018 and subsequent submission received by this department on 9 July 2018 refer.

Having considered the test reports ref. DP-SUMMARY-2018-1, DP-SUMMARY-2018-4 & EN0180111-26 issued on 25 May 2018, 16 June 2018 & 4 June 2018 by Castco Testing Centre Limited and the test report ref. RC1803760B issued on 1 June 2018 by The Lab (Asia) Ltd., this Authority accepts that the pipes and fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Shenzhen Hongtuo Shensu Plastic Science and Technology Co Ltd

Country of Origin: China

Brand: 深塑

Details of Pipes & Fittings: PE pipes and fittings in black colour (PE100, SDR11)

Description	Size (mm)
Pipe	25, 50, 110, 160



Description	Size (mm)
Electrofusion Tee	50
90° Electrofusion Elbow	50
Electrofusion Reducer	50x32

Body Markings:

For Pipe:

深塑 PE100 size x thickness SDR 11
 PN16 W BS EN 12201-2

For Fitting:

深塑 size description PE100 SDR 11
 PN16 BS EN 12201-3 e/f

Expiry Date:

1 April 2023

This Authority hereby permits the use of the above pipes and fittings in fresh water plumbing systems and flushing water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes and fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes and fittings installed fail to meet that of the approved samples or if the pipes and fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the pipes and fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes and fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,


 (CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



Electrofusion Tee



Electrofusion Reducer



90° Electrofusion Elbow