



總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/18 Pt.1 T/J(664)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

8 August 2018

**Approval of “TEGA” PE Fittings
(General Acceptance No. C20180507)**

Your letters dated 19 June 2018 and 4 July 2018 refer.

Having considered the test report ref. RC1803355(4) issued on 19 June 2018 by The Lab (Asia) Ltd. and WRAS approval no. 1806511, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Tega Engineering Industry & Trade Inc

Country of Origin: Turkey

Brand: Tega

Details of Fittings: PE fittings in black colour (PE100, SDR11)

Description	Size (mm)
Reduced Tee	250x180
Elbow 90°	250

Body Markings: TEGA

Expiry Date: 14 May 2023

This Authority hereby permits the use of the above fittings in fresh water plumbing systems and flushing water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



REDUCED TEE



ELBOW 90°