



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/18 Pt.1 T/J(745)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

17 August 2018

**Approval of "TEGA" PE Fittings
(General Acceptance No. C20180515)**

Your letters dated 4 July 2018 and 12 July 2018 refer.

Having considered the test reports ref. RC1803355, RC1803355(1), RC1803355(2) & RC1803355(3) all issued on 11 May 2018 by The Lab (Asia) Ltd. and WRAS approval no. 1806511, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Tega Engineering Industry & Trade Inc

Country of Origin: Turkey

Brand: Tega

Details of Fittings: PE fittings in black colour (PE100, SDR11)

Description	Size (mm)
Reducer	250x225, 355x315
Reduced Tee	355x180
Equal Tee	180, 250
Elbow 90°	180
Elbow 45°	180, 250, 355

Description	Size (mm)
Elbow 22.5°	180, 250, 355
Elbow 11.25°	180, 355

Body Markings: TEGA

Expiry Date: 26 April 2023

This Authority hereby permits the use of the above fittings in fresh water plumbing systems and flushing water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(WONG Yan-lok, Roger)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



Reducer



Reduced Tee



Equal Tee



Elbow 90°



Elbow 45°



Elbow 11.25°



Elbow 22.5°