



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/18 Pt.1 T/J(748)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

20 August 2018

**Approval of “HKS” Stainless Steel Pipes
(General Acceptance No. C20180519)**

Your letters ref. L18-0610 and L18-0702 dated 30 June 2018 and 16 July 2018 respectively refer.

Having considered the test report ref. BC-SUMMARY-2018-75 issued on 13 July 2018 by Castco Testing Centre Limited, this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: HK Steel Ltd

Country of Origin: Taiwan

Brand: HKS

Details of Pipes: Stainless steel pipe - Series 2 (304)

Model	Size
EN15105-4, EN151058-4, EN15105P-4, EN151058P-4	15mm
EN22125-4, EN221258-4, EN22125P-4, EN221258P-4, EN22125G-4, EN221258G-4	22mm
EN28125-4, EN281258-4, EN28125P-4, EN281258P-4, EN28125G-4, EN281258G-4	28mm

Model	Size
EN35155-4, EN351558-4, EN35155P-4, EN351558P-4	35mm
EN42155-4, EN421558-4, EN42155P-4, EN421558P-4	42mm
EN54155-4, EN541558-4, EN54155P-4, EN541558P-4	54mm

Body Markings: HKS BS EN 10312-S2 304 / 1.4301
size x thickness x length (Heat No.) TAIWAN

Expiry Date: 20 May 2023

This Authority hereby permits the use of the above pipes in fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed should be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fails to meet that of the approved samples or if the pipes are found to be unsuitable for use in fresh water plumbing systems.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(WONG Yan-lok, Roger)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only