



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (2) in WSD 3321/18 Pt.1 T/J(880)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

3 September 2018

**Approval of "PSV" Check Valves
(General Acceptance No. C20180579)**

Your letter ref. WSD-1403-18-L0001 dated 24 July 2018 refers.

Brand	Model No. (Size)	Fugro Test Report Ref.	Issuance Date
PSV	1403 (40mm)	182225EN181243	29 Jun 2018
PSV	1403 (50mm)	182225EN181243(1)	29 Jun 2018
PSV	1403 (65mm)	182225EN181243(2)	29 Jun 2018
PSV	1403 (80mm)	182225EN181243(3)	29 Jun 2018
PSV	1403 (100mm)	182225EN181243(4)	29 Jun 2018
PSV	1403 (150mm)	182225EN181243(5)	29 Jun 2018

Having considered the above test reports issued by the Fugro Technical Services Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: PSV Global Ltd UK

Country of Origin: China

Brand: PSV

Details of Fittings: Stainless steel silent check valve

Model: 1403
Size: 40mm, 50mm, 65mm, 80mm, 100mm, 150mm
Body Markings: PSV 1403 size in DN PN40
Expiry Date: 26 April 2023

This Authority hereby permits the use of the above fittings in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(Roger WONG)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



1403