



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/18 Pt.1 T/J(931)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

14 September 2018

**Approval of "HKS" Stainless Steel Fittings
(General Acceptance No. C20180617)**

Your letters ref. HFL18-0801 and HFL18-0404 dated 7 August 2018 and 13 August 2018 respectively refer.

Having considered the test report ref. BC-SUMMARY-2018-95 issued on 18 July 2018 by Castco Testing Centre Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: HK Steel Ltd

Country of Origin: China

Brand: HKS

Details of Fittings: Stainless steel fittings with grooved type connection (304)

Description	Size
45° Bend	54, 65, 80, 100 (mm)
90° Bend	54, 65, 80, 100 (mm)
KP Reducing Bend	65x54, 80x54 (mm)
Equal Tee	65, 80, 100 (mm)
Female Tee	54x1", 80x3", 100x3", 100x4" (mm x inch)

Description	Size
Reducing Tee	80x65, 100x65, 100x80 (mm)
KP Reducing Tee	65x54, 80x54, 100x54 (mm)
KP Cross Tee	65x54 (mm)
Coupling	54, 65, 80, 100 (mm)
Male Screw Coupler	54x2", 65x2½", 80x2½", 80x3", 100x2½", 100x4" (mm x inch)
Reducer	80x65, 100x65, 100x80 (mm)
KP Reducer	50x54, 65x54, 80x54, 100x54 (mm)

Body Markings:

For KP Reducing Tee, KP Cross Tee and KP Reducer:



304 - size

For Coupling:



size TP304 Kenlok

For others:



size - TP304

Expiry Date:

7 May 2023

This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed should be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,

(CHAN Chung-kun)

for Director of Water Supplies



45° Bend



90° Bend



KP Reducing Bend



Tee



Reducing Tee



KP Reducing Tee



KP Reducer



Reducer



KP Cross Tee



Coupling



Female Tee



Male Screw
Coupler