



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/18 Pt.1 T/J(939)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

14 September 2018

**Approval of "YL" Ductile Iron Fittings
(General Acceptance No. C20180619)**

Your letters ref. KK2017/DIPWSD/003CC and KK2018/DIPWSD/003CC dated 8 August 2018 and 21 August 2018 respectively refer.

Having considered the test report ref. BC-SUMMARY-2018-24 issued on 29 January 2018 by Castco Testing Centre Limited and WRAS certificate, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Liaoning Ever Metal Forming Tech Co Ltd

Country of Origin: China

Brand: YL

Details of Fittings: Ductile iron fittings with epoxy powder coating under WRAS approval no. 1707542

Description	Size
Double Flange 11.25° Bend	80, 100, 150, 200 (mm)
Double Flange 22.5° Bend	80, 100, 150, 200 (mm)
Double Flange 45° Bend	80, 100, 150, 200 (mm)
Double Flange 90° Bend	80, 100, 150, 200 (mm)
Double Socket 11.25° Bend	80, 100, 150, 200 (mm)

Description	Size
Double Socket 22.5° Bend	80, 100, 150, 200 (mm)
Double Socket 45° Bend	80, 100, 150, 200 (mm)
Double Socket 90° Bend	80, 100, 150, 200 (mm)

Body Markings:

For Double Flange Bend:
YL BSEN545 DI K12 PN16
size x angle Production code

For Double Socket Bend:
YL BSEN545 DI K12
size x angle Production code

Expiry Date:

31 July 2022

This Authority hereby permits the use of the above fittings in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



Double Socket
11.25° Bend



Double Socket
22.5° Bend



Double Socket
45° Bend



Double Socket
90° Bend



Double Flange
11.25° Bend



Double Flange
22.5° Bend



Double Flange
45° Bend



Double Flange
90° Bend