



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/18 Pt.1 T/J(1130)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

13 November 2018

**Approval of “DECO” Ductile Iron Fitting
(General Acceptance No. C20180768)**

Your letters both ref. SL20181001 dated 2 October 2018 and 11 October 2018 refer.

Having considered the test reports ref. BC-SUMMARY-2018-113 and 170515-0266 issued on 20 September 2018 and 12 December 2017 by Castco Testing Centre Limited, this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Liaoning Ever Metal Forming Tech Co Ltd

Country of Origin: the Mainland of China

Brand: Deco

Details of Fitting: Ductile iron fitting with cement mortar lining

Description	Size
Double Flange Taper (Concentric Type) (PN16)	80x50 (mm)

Body Markings: DECO production code BSEN 545 DI
K12 size x size PN16

Expiry Date: 24 July 2022

This Authority hereby permits the use of the above fitting in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fail to meet that of the approved sample or if the fitting is found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,


(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



Double Flange Taper
(Concentric Type) (PN16)