



總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/18 Pt.1 T/J(1131)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

19 November 2018

**Approval of "CISAL" Mechanical Mixers and Tap
(General Acceptance No. C20180779)**

Your letters ref. CT18/4887 and CT18/4887-1 dated 4 October 2018 and 24 October 2018 respectively refer.

Brand	Model No.	Nutek Test Report Ref.	Issuance Date
Cisal	TR40053021	J23479r1	24 Oct 2018
Cisal	TR40072021	J23480r1	24 Oct 2018
Cisal	TR40074021	J23481r1	24 Oct 2018

Having considered the above test reports issued by Nutek Systems (HK) Ltd., this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Cisal SRL

Country of Origin: Italy

Brand: Cisal

Details of Fitting: 1. 3/8" Sink mixer supplied with 2 nos. of flexible hoses approved by UK's WRAS under ref. 1710803
Model: TR40053021

2. 1/2" Washbasin mixer
Model: TR40072021

3. 1/2" Pillar tap
Model: TR40074021

Body Markings:



Expiry Date:

11 September 2023 (for TR40053021 & TR40074021)

16 September 2023 (for TR40072021)

31 October 2022 (for hose)

This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"The cold water supply to the fittings shall be drawn from the same source that supplies the hot water apparatus so as to provide a balanced pressure and to obviate the risk of scalding in the event of a restriction or failure in the water supply."

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fittings, unless other specified.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,

(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



TR40053021



TR40074021



TR40072021