



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/18 Pt.1 T/J(1143)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

19 November 2018

**Approval of “TOZEN” Flexible Joint
(General Acceptance No. C20180781)**

Your letters ref. TLL/M807/18 and TLL/M811/18 dated 9 October 2018 and 24 October 2018 respectively refer.

Having considered the test report ref. J23579 issued on 5 October 2018 by Nutek Systems (HK) Ltd. and test report ref. EN0161202-24 issued on 24 February 2017 by Castco Testing Centre Limited, this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Tozen Corporation
Country of Origin: the Mainland of China
Brand: Tozen
Details of Fitting: Rubber flexible joint with flanged end connection
Model: Twinflex
Size: 350mm
Body Markings: TOZEN TWINFLEX 350 (14)



Expiry Date: 23 January 2022

This Authority hereby permits the use of the above fitting in fresh water plumbing systems, flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fail to meet that of the approved sample or if the fitting is found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



Twinflex