



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/18 Pt.1 T/J(1178)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

21 November 2018

**Approval of “SEAH” Galvanized Steel Pipes
(General Acceptance No. C20180791FS)**

Your letters dated 18 October 2018 and 25 October 2018 refer.

Having considered the test report ref. BC-SUMMARY-2018-115 issued on 21 September 2018 by Castco Testing Centre Limited, this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: SeAH Steel Corp
Country of Origin: Korea
Brand: SeAH
Details of Pipes: Galvanized steel pipe
Size: 250mm, 300mm, 350mm
Body Markings: SēAH SeAH STEEL EW EN10217-1:2002 P265TR1
C2 size x thickness x length MADE IN KOREA
KHK production code
Expiry Date: 7 September 2023



Proviso: The pipes can only be used in fresh water fire service plumbing systems.

This Authority hereby permits the use of the above pipes in fresh water fire service plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fails to meet that of the approved samples or if the pipes are found to be unsuitable for use in fresh water fire service plumbing systems.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only