



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (5) in WSD 3321/18 Pt.1 T/J(1233)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

3 December 2018

**Approval of "RIGEL" Sensor Taps
(General Acceptance No. C20180824)**

Your letters dated 30 October 2018 and 14 November 2018 refer.

Having considered the test reports ref. J23434A, J23435A, J23436A, J23437A, J23438A and J23439A all issued on 2 November 2018 by Nutek Systems (HK) Ltd. and WRAS certificate, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Rigel Technology (S) Pte Ltd

Country of Origin: the Mainland of China

Brand: Rigel

Details of Fittings: 1/2" Sensor tap supplied with one of flexible hose approved by UK's WRAS under ref. 1705555

Model: RL-ST303Vy-xx-HKM, RL-ST103SSNy-xx-HKM, RL-ST310GNy-xx-HKM, RL-ST310GNXy-xx-HKM, RL-ST103WNY-xx-HKM, RL-ST103SWy-xx-HKM (where "y" denote the power source and "xx" denote the spout colour)

Body Markings:

For RL-ST303Vy-xx-HKM, RL-ST310GNy-xx-HKM
and RL-ST310GNXy-xx-HKM:

RIGEL

For RL-ST103SSNy-xx-HKM, RL-ST103WNY-xx-HKM
and RL-ST103SWy-xx-HKM:



RIGEL

Expiry Date:

31 May 2022 (for tap + hose)

This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"A stop cock or gate valve must be installed at the upstream of the fittings for manual isolation of water supply." AND

"The main voltage operated sensor valve should comply with the electricity safety regulation for applications in bathroom, toilet etc."

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fittings, unless other specified.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,

(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



RL-ST303Vy-xx-HKM



RL-ST103SSNy-xx-HKM



RL-ST310GNy-xx-HKM



RL-ST310GNXy-xx-HKM



RL-ST103WNy-xx-HKM



RL-ST103SWy-xx-HKM