



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (8) in WSD 3321/18 Pt.1 T/J(222)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

7 December 2018

**Approval of "INAX" Sensor Taps
(General Acceptance No. C20180843)**

Your letters ref. WRC/1571, C-WSD/0345, C-WSD/0392 and C-WSD/0481 dated 22 February 2018, 26 March 2018, 9 May 2018 and 20 November 2018 respectively refer.

Having considered the test reports ref. J21691Ar2 and J21657r1 issued on 30 April 2018 and 20 April 2018 by Nutek Systems (HK) Ltd., this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: INAX

Country of Origin: the Mainland of China

Brand: INAX

Details of Fitting: 1/2" Electronic sensor basin tap with 1 no. of rubber hose

Model: AMC140C-WP and AMC140CA-WP

Body Markings: 

Expiry Date: 28 August 2022 (for tap + hose)

This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"A stop cock or gate valve must be installed at the upstream of the fittings for manual isolation of water supply." AND

"The main voltage operated sensor valve should comply with the electricity safety regulation for applications in bathroom, toilet etc."

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fittings, unless other specified.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



AMC140C-WP



AMC140CA-WP