



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/18 Pt.1 T/J(1239)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

7 December 2018

**Approval of "PEGLER" Float Valves
(General Acceptance No. C20180845F)**

Your letters ref. Q-0160/18 and Q-0165/18 dated 8 November 2018 and 16 November 2018 respectively refer.

Having considered the test report ref. BC-SUMMARY-2018-88 issued on 7 August 2018 by Castco Testing Centre Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Pegler Yorkshire
Country of Origin: UK
Brand: Pegler
Details of Fitting: Copper alloy equilibrium float valve
Model: 901BL
Size: 32mm, 40mm, 50mm, 65mm, 80mm, 100mm, 150mm
Body Markings: PEGLER ENGLAND 901 (DN)

Expiry Date: 20 June 2023

Proviso: The fittings can only be used in flushing water plumbing systems and salt water fire services systems.

This Authority hereby permits the use of the above fittings in flushing water plumbing systems and salt water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



901BL