



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/18 Pt.1 T/J(1248)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

7 December 2018

**Approval of “CISAL” Mechanical Mixers
(General Acceptance No. C20180846)**

Your letters ref. CT18/4888 and CT18/4888-1 dated 9 November 2018 and 22 November 2018 respectively refer.

Brand	Model No.	Nutek Test Report Ref.	Issuance Date
Cisal	XXX0053YYY	J23482r1	7 Nov 2018
Cisal	XXX0044YYY	J23483r2	22 Nov 2018
Cisal	XXX0051YYY	J23484r1	7 Nov 2018
Cisal	XXX0013YYY	J23485r1	7 Nov 2018
Cisal	XXX0052YYY	J23486r1	8 Nov 2018

Having considered the above test reports issued by Nutek Systems (HK) Ltd., this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Huber Cisal Industrie SpA

Country of Origin: Italy

Brand: Cisal

Details of Fitting:

1. 3/8" Single lever sink mixer supplied with 2 nos. of flexible hoses approved by UK's WRAS under ref. 1710803
Model: XXX0053YYY & XXX0052YYY
2. 1/2" Single lever shower mixer
Model: XXX0044YYY
3. 3/8" Single lever basin mixer supplied with 2 nos. of flexible hoses approved by UK's WRAS under ref. 1710803
Model: XXX0051YYY
4. 1/2" Single lever bath mixer
Model: XXX0013YYY

(where the digits "XXX" denote the code of handle and "YYY" denote the code of finish)

Body Markings:**cisal****Expiry Date:**

11 September 2023 (for mixer)
31 October 2022 (for hose)

This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"The cold water supply to the fittings shall be drawn from the same source that supplies the hot water apparatus so as to provide a balanced pressure and to obviate the risk of scalding in the event of a restriction or failure in the water supply." AND

"The shower head or handspray should not be placed in submerged conditions and should be securely fixed to the original position after use."

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fittings, unless other specified.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



XXX0051YYY



XXX0053YYY



XXX0052YYY



XXX0013YYY



XXX0044YYY