



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (2) in WSD 3321/18 Pt.1 T/J(1295)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

17 December 2018

**Approval of “BOWLING (JM)” Galvanized Steel Pipes
(General Acceptance No. C20180873FS)**

Your letter ref. BK2018-VM-1026 dated 20 November 2018 refers.

Having considered the test report ref. BC-SUMMARY-2018-122 issued on 6 November 2018 by Castco Testing Centre Limited, this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Jinan Mech Piping Technology Co Ltd

Country of Origin: the Mainland of China

Brand: Bowling (JM)

Details of Pipes: Galvanized steel pipe (class medium)

Size: 25mm, 32mm, 40mm, 50mm, 65mm, 80mm, 100mm, 150mm

Body Markings: Bowling EN10255:2004 SERIES MEDIUM
W size x length JM production code

Expiry Date: 31 October 2023

Proviso: The pipes can only be used in fresh water fire service plumbing systems.

This Authority hereby permits the use of the above pipes in fresh water fire service plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fails to meet that of the approved samples or if the pipes are found to be unsuitable for use in fresh water fire service plumbing systems.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only