



總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/19 Pt.1 T/J(3)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

21 February 2019

Approval of "TIPO" Copper Fittings (General Acceptance No. C20190139)

Your letters dated 2 January 2019 and 24 January 2019 refer.

Having considered the test reports ref. 183431PC180081A, 183431PC180081(1)A and 183431PC180081(2)A all issued on 21 January 2019 by Fugro Technical Services Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Wenling Honson Brassware Co Ltd

Country of Origin: the Mainland of China

Brand: Tipo

Details of Fittings: Copper alloy fittings with compression end

Description	Model	Size
Straight Coupler	301	22x15 (mm)
Male Coupler	302	22x½" (mm x inch)
Female Coupler	303	22x½" (mm x inch)
Elbow	401	22x15 (mm)
Male Elbow	402	15x¾", 22x½" (mm x inch)

Description	Model	Size
Tee	601	22x15x22, 22x22x15 (mm)
Female Tee	617	22x22x $\frac{3}{4}$ " (mm x mm x inch)

Body Markings: TIPO EN 1254-2 size

Expiry Date: 29 October 2023

This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed should be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



Male Coupler



Straight Coupler



Male Elbow



Elbow



Female Coupler



Tee



Female Tee