



水務署  
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : ( 6 ) in WSD 3321/18 Pt.1 T/J(968)  
Our ref.  
來函檔號 :  
Your ref.

電話 :  
Tel.  
傳真 : 2824 0578  
Fax.

28 February 2019

Approval of “深塑” uPVC Pipe  
(General Acceptance No. C20190154F)

Your letter dated 21 August 2018 and subsequent submission received by this department on 20 February 2019 refer.

Having considered the test report ref. DP-SUMMARY-2018-9 issued on 28 November 2018 by Castco Testing Centre Limited, this Authority accepts that the pipe described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

**Name of Manufacturer:** Shenzhen Hongtuo Shensu Plastic Science and Technology Co Ltd

**Country of Origin:** the Mainland of China

**Brand:** 深塑

**Details of Pipe:** uPVC Pipe in white colour

| Model   | Size |
|---------|------|
| 1065037 | 50mm |

**Body Markings:** 深塑 PVC-U DN50 3.7 SDR 13.6 PN16  
BS EN ISO 1452-2 201801112



**Expiry Date:** 13 March 2023

**Proviso:** As the pipe has not been tested for use in contact with water intended for human consumption, the pipe can only be used in flushing water plumbing system.

This Authority hereby permits the use of the above pipe in flushing water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipe to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipe installed fails to meet that of the approved sample or if the pipe is found to be unsuitable for use in flushing water plumbing systems.

For the use of the pipe in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipe by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c.      WSD 3321/1/82   ] - without catalogue  
            ME/MC        ] - with soft copy only