



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (8) in WSD 3321/19 Pt.1 T/J(21)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

25 March 2019

**Approval of "RIGEL" Sensor Flush Valves
(General Acceptance No. C20190211F)**

Your letter dated 20 December 2018 and subsequent submission received by this department on 14 March 2019 refer.

Having considered the test reports ref. J23461A-1, J23461A-2 and J23461A-4 all issued on 4 January 2019 by Nutek Systems (HK) Ltd., this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Rigel Technology (S) Pte Ltd

Country of Origin: the Mainland of China

Brand: Rigel

Details of Fitting: 1/2" Urinal sensor flush valve

Model: RL-AFS202DFGxxSey-SW
RL-AFS202DGxxSey-SW
RL-AFS202CFGxxSey-SW
RL-AFS202CGxxSey-SW
RL-AFS202Cxxxy-SW
RL-AFS202Dxxxy-SW
(where "xx" denotes the type of face plate and "y" denotes the power source)

Body Markings:

RIGEL

Expiry Date:

7 October 2023

Proviso: As the fittings have not been tested for use in contact with water intended for human consumption, the fittings can only be used in flushing water plumbing system.

This Authority hereby permits the use of the above fittings in flushing water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"Installation of filter before flushing valve is required. Without the filter, the flushing valve is liable to leak. The installed filter need frequent inspection and cleaning to maintain flushing supply. Normally only public toilets with good management system for maintenance would be considered."

"A stop cock or gate valve must be installed at the upstream of the fitting for manual isolation of water supply."

"The design flushing volume of the flushing valve should be compatible with the toilet bowl to ensure that effective clearance can be achieved by a single flush of water."

"Flushing valve should be used within the range of working pressures specified by the manufacturer." AND

"Installation of electronic opening and closing sanitary tapware should also comply with the requirements of Electrical & Mechanical Services Department."

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in flushing water plumbing systems.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,

A handwritten signature in black ink, appearing to be 'mh' followed by a long horizontal stroke.

(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



RL-AFS202DFGxxSey-SW



RL-AFS202DGxxSey-SW



RL-AFS202CFGxxSey-SW



RL-AFS202CGxxSey-SW



RL-AFS202Cxxxy-SW



RL-AFS202Dxxxy-SW