



總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/19 Pt.1 T/J(234)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

8 April 2019

Approval of "HW" Stainless Steel Fittings (General Acceptance No. C20190244)

Your letters dated 6 March 2019 and 22 March 2019 refer.

Having considered the test report ref. BC-SUMMARY-2018-143 issued on 12 December 2018 by Castco Testing Centre Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Hopewell Building Materials Co Ltd

Country of Origin: the Mainland of China

Brand: HW

Details of Fittings: Stainless steel fittings with press ends connection (304)

Description	Size
Equal Coupling	76.1, 88.9, 108 (mm)
Adjustable Coupling	76.1, 88.9, 108 (mm)
Male Coupling	76.1x2½", 88.9x3" (mm x inch)
Reducer - A	76.1x54, 88.9x54, 108x54, 108x76.1, 108x88.9 (mm)
Reducer - B	76.1x54, 88.9x54, 108x54, 108x88.9 (mm)
90° Short Equal Elbow	76.1, 88.9, 108 (mm)

Description	Size
90° Short Plain Elbow - B	76.1, 88.9, 108 (mm)
45° Elbow	76.1, 88.9 (mm)
45° Plain Elbow - B	76.1, 88.9, 108 (mm)
Equal Tee	76.1, 88.9, 108 (mm)
Reducing Tee	76.1x54, 88.9x54, 88.9x76.1, 108x54, 108x76.1, 108x88.9 (mm)
Female Tee	76.1x2", 88.9x2", 108x2" (mm x inch)

Body Markings: HW size - 304

Expiry Date: 29 November 2023

This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed should be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,




(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only




Equal Coupling



Adjustable Coupling



Male Coupling



Reducer - A



Reducer - B



90° short
equal elbow



90° short Plain Elbow - B



45° equal elbow



45° plain elbow - B



Equal Tee



Reducing Tee



Female Tee