



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (6) in WSD 3321/19 Pt.1 T/J(111)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

11 April 2019

**Approval of "KOHLER" Sensor Tap
(General Acceptance No. C20190249)**

Your letters ref. HX/W/0328/19, HX/W/0641/19 and HX/W/0758/19 dated 28 January 2019, 6 March 2019 and 20 March 2019 respectively refer.

Having considered the test report ref. 155629ST160701(4)I issued on 15 March 2019 by Fugro Technical Services Limited and WRAS Certificate, this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Shanghai Kohler Electronics Ltd

Country of Origin: the Mainland of China

Brand: Kohler

Details of Fitting: 1/2" Electronic sensor tap with flexible hose approved by UK's WRAS under ref. 1704079

Model: K-18655H-XX
(where "XX" denote the codes of finish)

Body Markings: Kohler

Expiry Date:

14 November 2021

This Authority hereby permits the use of the above fitting in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"A stop cock or gate valve must be installed at the upstream of the fitting for manual isolation of water supply." AND

"The main voltage operated sensor valve should comply with the electricity safety regulation for applications in bathroom, toilet etc."

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fitting, unless otherwise specified.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



K-18655H-XX