



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/19 Pt.1 T/J(258)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

24 April 2019

**Approval of "GEBERIT" Stainless Steel Pipes
(General Acceptance No. C20190260)**

Your letters dated 15 March 2019 and 4 April 2019 refer.

Having considered the test report ref. BC-SUMMARY-2019-8 issued on 22 March 2019 by Castco Testing Centre Limited, this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Geberit

Country of Origin: Germany

Brand: Geberit

Details of Pipes: Stainless steel pipe - Series 2 (316)

Size: 15mm, 22mm, 28mm, 35mm, 42mm, 54mm, 76.1mm, 88.9mm, 108mm

Body Markings: GEBERIT Geberit Mapress (Production Code)
(Diameter) x (Wall Thickness) 1.4401 / 316

Expiry Date: 19 February 2024

This Authority hereby permits the use of the above pipes in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fail to meet that of the approved samples or if the pipes are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only