



總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (2) in WSD 3321/19 T/J(422/2019)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

27 May 2019

**Approval of “ASAHI” uPVC Valves and Strainers
(General Acceptance No. C20190303F)**

Your letter ref. BK2019-VM-1030 dated 8 April 2019 refers.

Having considered the test report ref. BC-SUMMARY-2019-12 issued on 8 March 2019 by Castco Testing Centre Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Asahi Yukizai Corporation

Country of Origin: Japan

Brand: Asahi

Details of Fittings:

1. uPVC Grey Single Union Ball Check Valves – Socket Ends
Size: 15mm, 20mm
2. uPVC Grey Y-Sediment Strainer – Socket Ends
Size: 65mm

Body Markings:

For uPVC Grey Single Union Ball Check Valves – Socket Ends:

⊗ ASAHI AV VALVE MADE IN JAPAN (DN)
(Inch) FLOW DIRECTION ➡

For uPVC Grey Y-Sediment Strainer – Socket Ends:

⊗ ASAHI AV VALVE MADE IN JAPAN
STRAINER (DN) - (Inch) ➡

Expiry Date:

16 January 2024

Proviso: As the fittings have not been tested for use in contact with water intended for human consumption, the fittings can only be used in flushing water plumbing system.

This Authority hereby permits the use of the above fittings in flushing water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in flushing water plumbing systems.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



Grey Single Union Ball Check Valve -Socket Ends



Grey Y-Sediment Strainer - Socket Ends