



總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (2) in WSD 3321/19 T/J(457/2019)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

6 June 2019

[Faint, illegible text, likely a watermark or bleed-through from the reverse side of the page]

**Approval of “TOYO” Gate Valves
(General Acceptance No. C20190320FS)**

Your letter ref. GWL/19/0515 dated 15 May 2019 refers.

Having considered the test report ref. BC-SUMMARY-2019-19 issued on 11 April 2019 by Castco Testing Centre Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer:	Kitz Corporation
Country of Origin:	the Mainland of China
Brand:	Toyo
Details of Fitting:	Cast iron gate valve
Model:	501SHK
Size:	65mm, 80mm, 100mm, 125mm, 150mm, 200mm, 250mm, 300mm
Body Markings:	size in DN PN16 CI TOYO

Expiry Date: 7 April 2024

Proviso: The fittings can only be used in fresh water fire services systems.

This Authority hereby permits the use of the above fittings in fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water fire services systems.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



501SHK