



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (8) in WSD 3321/19 Pt.1 T/J(367)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

18 July 2019

**Approval of "PSV" Ball Valves
(General Acceptance No. C20190365FS)**

Your letter ref. WSD-1800-19-L002 dated 16 April 2019 and subsequent submission received by this department on 2 July 2019 refer.

Brand	Model No. (Size)	Fugro Test Report Ref.	Issuance Date
PSV	1800 (25mm)	183442PC180064C	25 May 2019
PSV	1800 (32mm)	183442PC180064(1)C	25 May 2019
PSV	1800 (50mm)	183442PC180064(2)D	17 Jun 2019

Having considered the above test reports issued by the Fugro Technical Services Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: PSV Global Ltd UK
Country of Origin: the Mainland of China
Brand: PSV
Details of Fittings: Copper alloy ball valve
Model: 1800



Size: 25mm, 32mm, 50mm

Body Markings: 

Expiry Date: 8 November 2023

Proviso: The fittings can only be used in fresh water fire service plumbing systems.

This Authority hereby permits the use of the above fittings in fresh water fire service plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water fire service plumbing systems.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,




(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



1800