



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/19 T/J(507/2019)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

2 August 2019

**Approval of “SHOWA” Gate Valves
(General Acceptance No. C20190398F)**

Your letters ref. WL-19/006 and WL-19/008 dated 23 May 2019 and 17 July 2019 respectively refer.

Brand	Model No. (Size)	Fugro Test Report Ref.	Issuance Date
Showa	Fig.104WR (80mm)	186761PC180217B	12 Jul 2019
Showa	Fig.104WR (100mm)	186761PC180217(1)B	12 Jul 2019
Showa	Fig.104WR (150mm)	186761PC180217(2)B	12 Jul 2019

Having considered the above test reports issued by the Fugro Technical Services Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Showa Valve Co Ltd

Country of Origin: the Mainland of China

Brand: Showa

Details of Fittings: Cast iron gate valve

Model: Fig.104WR
Size: 80mm, 100mm, 150mm
Body Markings: Size in DN CI  Production Year
 EN1074-2 PN25
Expiry Date: 1 February 2024

Proviso: The fittings can only be used in flushing water plumbing systems and fresh water fire services systems.

This Authority hereby permits the use of the above fittings in flushing water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



Fig. 104WR