



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (7) in WSD 3321/19 T/J(657/2019)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

20 September 2019

**Approval of "PSV" Pressure Reducing Valves
(General Acceptance No. C20190480)**

Your letter ref. WSD-2290-19-L001 dated 5 July 2019 and subsequent submission received by this department on 12 September 2019 refer.

Brand	Model No. (Size)	Fugro Test Report Ref.	Issuance Date
PSV	2290 (50mm)	180059PC190088(4)B	4 Sept 2019
PSV	2290 (65mm)	180059PC190088(5)B	4 Sept 2019
PSV	2290 (80mm)	180059PC190088(6)B	4 Sept 2019
PSV	2290 (100mm)	180059PC190088(7)B	4 Sept 2019

Having considered the above test reports issued by the Fugro Technical Services Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: PSV Global Ltd UK

Country of Origin: the Mainland of China

Brand: PSV

Details of Fitting: Stainless steel pressure reducing valve

Model: 2290

Size: 50mm, 65mm, 80mm, 100mm

Body Markings: ➡ PSV size in inch

Expiry Date: 21 February 2024

This Authority hereby permits the use of the above fittings in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(CHEUNG Yip-kui)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



2290