



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (6) in WSD 3321/19 T/J(846/2019)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

24 October 2019

**Approval of “TOZEN” Flexible Joints
(General Acceptance No. C20190520)**

Your letters ref. TLL/M830/19, TLL/M831/19 and TLL/M832/19 dated 19 August 2019, 19 September 2019 and 3 October 2019 respectively refer.

Having considered the test reports ref. J24565Ar1 and J24565Br2 issued on 17 September 2019 and 2 October 2019 by Nutek Systems (HK) Ltd., this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Tozen Corporation
Country of Origin: Thailand
Brand: Tozen
Details of Fitting: Stainless steel flexible joint
Model: SF-600-316F
Size: 50mm, 80mm
Body Markings: Nil



香港環境卓越大獎
Hong Kong Awards for Environmental Excellence



Expiry Date: 4 August 2024

This Authority hereby permits the use of the above fittings in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fail to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,




(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



SF-600-316F