



水務署  
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : ( 5 ) in WSD 3321/19 T/J(928/2019)  
Our ref.  
來函檔號 :  
Your ref.

電話 :  
Tel.  
傳真 : 2824 0578  
Fax.

27 November 2019

**Approval of "HKS" Stainless Steel Fittings  
(General Acceptance No. C20190571)**

Your letter ref. HFL19-0902 dated 3 September 2019 and subsequent submission received by this department on 31 October 2019 refer.

Having considered the test report ref. BC-SUMMARY-2019-56 issued on 16 July 2019 by Castco Testing Centre Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

**Name of Manufacturer:** HK Steel Ltd

**Country of Origin:** the Mainland of China

**Brand:** HKS

**Details of Fittings:** Stainless steel fittings with grooved type connection (316)

| Description     | Size          |
|-----------------|---------------|
| 45° Bend        | 150, 200 (mm) |
| 90° Bend        | 150, 200 (mm) |
| Equal Tee       | 150, 200 (mm) |
| 45° Lateral Tee | 150 (mm)      |
| KP Reducing Tee | 150x54 (mm)   |

| Description        | Size                                  |
|--------------------|---------------------------------------|
| Reducing Tee       | 150x65, 150x80, 150x100 (mm)          |
| Coupling           | 150, 200 (mm)                         |
| Male Screw Coupler | 150x6" (mm x inch)                    |
| KP Reducer         | 150x54 (mm)                           |
| Reducer            | 150x65, 150x80, 150x100, 200x150 (mm) |
| Eccentric Reducer  | 150x100 (mm)                          |

**Body Markings:** For Coupling:  
HKS size TP 316 Kenlok

For others:  
HKS size TP 316

**Expiry Date:** 4 August 2024

This Authority hereby permits the use of the above fittings in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed should be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82 ] - without catalogue  
ME/MC ] - with soft copy only



**45° Bend**



**90° Bend**



**Equal Tee**



**Reducing Tee**



**KP Reducing Tee**



**Eccentric Reducer**



**KP Reducer**



**Reducer**



**Coupling**



**Male Screw Coupler**



**45° Lateral Tee**