



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/19 T/J(955/2019)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

27 November 2019

**Approval of "TUB-E" Copper Pipe
(General Acceptance No. C20190572)**

Your letters ref. BK2019-VM-1047 and BK2019-VM-1047(R1) dated 10 September 2019 and 28 October 2019 respectively refer.

Having considered the test report ref. DP-SUMMARY-2019-3 issued on 18 October 2019 by Castco Testing Centre Limited, this Authority accepts that the pipe described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Mueller Europe Limited

Country of Origin: UK

Brand: tub-e

Details of Pipe: Copper pipe (Table X)

Temper	Size (mm)
R290	159 x 2

Body Markings: 159mm-tub-e ® PREMIUM
BS EN 1057 159 x 2.0 R290

Expiry Date: 11 October 2024

This Authority hereby permits the use of the above pipe in fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipe to be installed should be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipe installed fails to meet that of the approved sample or if the pipe is found to be unsuitable for use in fresh water plumbing systems.

For the use of the pipe in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipe by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only