



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/19 T/J(1154/2019)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

20 January 2020

**Approval of “SEAH (PSP)” Black Steel Pipe
(General Acceptance No. C20200052FS)**

Your letters ref. BK2019-VM-1052 and BK2019-VM-1052(R1) dated 29 November 2019 and 27 December 2019 respectively refer.

Having considered the test report ref. BC-SUMMARY-2019-68 issued on 11 November 2019 by Castco Testing Centre Limited, this Authority accepts that the pipe described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: SeAH Steel Corporation

Country of Origin: South Korea

Brand: SeAH (PSP)

Details of Pipe: 400 x 8mm Black steel pipe

Body Markings: SeAH SeAH Steel EW EN10217-1:2002 P265TR1
C2 400A x 8.0 x 6M PSP MADE IN KOREA
BUN KEE PRODUCTION CODE

Expiry Date: 27 October 2024

Proviso: The pipe can only be used in fresh water fire service systems.

This Authority hereby permits the use of the above pipe in fresh water fire service systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipe to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipe installed fails to meet that of the approved sample or if the pipe is found to be unsuitable for use in fresh water fire service systems.

For the use of the pipe in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipe by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only