



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2020 T/J(730/2020)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

14 August 2020

**Approval of “WATERTEC” Flexible Hose
(General Acceptance No. C20200675)**

Your letters ref. SWC-2488-19r5 and SWC-2488-19r6 dated 16 June 2020 and 10 July 2020 respectively refer.

Having considered the test reports ref. 154605EN151617C issued on 3 June 2019 by Fugro Technical Services Limited and ref. 190729-2104/191122-2292 issued on 17 January 2020 by Castco Testing Centre Limited, this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Watertec (Malaysia) Sdn Bhd
Country of Origin: Malaysia
Brand: Watertec
Details of Fitting: Plastic inlet flexible hose for tap/mixer
Model: WA-PERTCON-100
Size: Bore diameter: 10mm
End connection: 1/2"

Body Markings: Watertec PERT Class 2 / 10 bar at Max. Temp 85°C

Expiry Date: 3 December 2024

This Authority hereby permits the use of the above fitting in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"The inlet flexible hose is applied for the water tap or mixer connection only and installed in the fresh water plumbing systems."

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water plumbing systems.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



WA-PERTCON-100