



水務署  
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : ( 6 ) in WSD 3321/2020 T/J(725/2020)  
Our ref.  
來函檔號 :  
Your ref.

電話 :  
Tel.  
傳真 : 2824 0578  
Fax.

26 August 2020

**Approval of "RUBY" Bib Taps  
(General Acceptance No. C20200717)**

Your letters dated 15 June 2020, 30 June 2020 and 22 July 2020 refer.

Having considered the test report ref. RSLK004r1 issued on 22 July 2020 by Ideal Test Consultants Ltd., this Authority accepts that the fittings described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

**Name of Manufacturer:** Jinyi Valve Co Ltd  
**Country of Origin:** the Mainland of China  
**Brand:** Ruby  
**Details of Fittings:** 1/2" Bib tap  
**Model:** NC988 and NC988K  
**Body Markings:** RUBY BS1010  
**Expiry Date:** 4 June 2025

This Authority hereby permits the use of the above fittings in fresh water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fittings, unless otherwise specified.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c.      WSD 3321/1/82    ] - without catalogue  
            ME/MC            ] - with soft copy only



NC988



NC988K