



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (6) in WSD 3321/2020 T/J(811/2020)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

14 September 2020

**Approval of "DORNBRACHT" Basin Mixer
(General Acceptance No. C20200799)**

Your letters ref. D73A/2020/0511, D73A/2020/0581 and D73A/2020/0670 dated 30 June 2020, 28 July 2020 and 28 August 2020 respectively refer.

Having considered the test report ref. J24757Ar3 issued on 25 August 2020 by Nutek Systems (HK) Ltd. and WRAS certificate, this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: Aloys F Dornbracht GmbH & Co KG

Country of Origin: Germany

Brand: Dornbracht

Details of Fitting: 1/2" Three-hole basin mixer with 2 nos. of flexible hoses approved by UK's WRAS under ref. 2005316

Model: 20.700.3Y0.XX
(where "Y" denotes the code of series and "XX" denotes the variation in finishes)

Body Markings:



Expiry Date: 26 September 2024

This Authority hereby permits the use of the above fitting in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"The cold water supply to the fitting shall be drawn from the same source that supplies the hot water apparatus so as to provide a balanced pressure and to obviate the risk of scalding in the event of a restriction or failure in the water supply."

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fitting, unless otherwise specified.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only



20.700.3Y0.XX