



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (6) in WSD 3321/2020 T/J(755/2020)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

25 September 2020

**Approval of “KING LION” UPVC Fittings
(General Acceptance No. C20200855F)**

Your letter ref. HK/KLSD/LL20/047 dated 22 June 2020 and subsequent submissions received by this department up to 20 August 2020 refer.

Having considered the test report ref. 182923ST180406D issued on 23 July 2020 by Fugro Technical Services Limited, this Authority accepts that the fittings described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: King Lion PVC Pipes & Fittings MFY Ltd

Country of Origin: the Mainland of China

Brand: King Lion

Details of Fittings: uPVC fittings in white colour

Description	Size (mm)
Reducing Tee	20x20x15, 25x25x15, 32x32x15, 40x40x15, 50x50x15, 25x25x20, 32x32x20, 40x40x20, 50x50x20, 32x32x25, 40x40x25, 50x50x25, 40x40x32, 50x50x32, 50x50x40
90° Tee	15, 20, 25, 32, 40, 50
45° Bend	15, 20, 25, 32, 40, 50

Description	Size (mm)
90° Bend	15, 20, 25, 32, 40, 50
Reducer	32x15, 15x20, 25x15, 40x15, 50x15, 25x20, 32x20, 40x20, 50x20, 32x25, 40x25, 50x25, 40x32, 50x32, 50x40

Body Markings:

For Reducing Tee and Reducer:



size x size

For 45° Bend:



size x angle

For 90° Tee and 90° Bend:



size

Expiry Date:

7 October 2023

Proviso: As the fittings have not been tested for use in contact with water intended for human consumption, the fittings can only be used in flushing water plumbing system.

This Authority hereby permits the use of the above fittings in flushing water plumbing systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the fittings to be installed shall be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fittings installed fails to meet that of the approved samples or if the fittings are found to be unsuitable for use in flushing water plumbing systems.

For the use of the fittings in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fittings by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.


Yours faithfully,

(CHAN Chung-kun)


for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only



Reducing Tee



90° Tee



Reducer



45° Bend



90° Bend