



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (2) in WSD 3321/2020 T/J(1256/2020)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

15 October 2020

**Approval of "SEAH" Galvanized Steel Pipe
(General Acceptance No. C20200925FS)**

Your letter dated 15 September 2020 refers.

Having considered the test report ref. BC-SUMMARY-2020-112 issued on 12 August 2020 by Castco Testing Centre Limited, this Authority accepts that the pipe described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: SeAH Steel Corporation

Country of Origin: Korea

Brand: SeAH

Details of Pipe: 200mm x 5.6mm Galvanized steel pipe

Body Markings: SēAH SeAH STEEL EW EN10217-1 P265 TR1
C2 size x thickness x length MADE IN KOREA
KHK

Expiry Date: 5 August 2025

Proviso: The pipe can only be used in fresh water fire service systems.


This Authority hereby permits the use of the above pipe in fresh water fire service systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipe to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipe installed fails to meet that of the approved sample or if the pipe is found to be unsuitable for use in fresh water fire service systems.

For the use of the pipe in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipe by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
ME/MC] - with soft copy only