



水務署
Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號入境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 : (4) in WSD 3321/2020 T/J(1191/2020)
Our ref.
來函檔號 :
Your ref.

電話 :
Tel.
傳真 : 2824 0578
Fax.

28 October 2020

**Approval of “KEMBLA” Copper Pipes
(General Acceptance No. C20200963)**

Your letters dated 2 September 2020 and 15 October 2020 refer.

Having considered the test report ref. BC-SUMMARY-2020-104 issued on 14 October 2020 by Castco Testing Centre Limited, this Authority accepts that the pipes described below comply with, and their use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer: MM Kembla

Country of Origin: Australia

Brand: Kembla

Details of Pipes: 1. Bare copper pipes (Table Y)

Temper	Size (mm)
R250	15x1.0, 22x1.2, 28x1.2
R290	35x1.5

2. Copper pipes with plastic sheath (Table Y) (Kemline) (cold water)

Temper	Size (mm)
R250	15x1.0, 22x1.2, 28x1.2
R290	35x1.5

Body Markings:

For Bare copper pipes (Table Y) (R250):
 KEMBLA – MADE IN AUSTRALIA
 EN1057 – Y size X thickness HH

For Bare copper pipes (Table Y) (R290):
 KEMBLA – MADE IN AUSTRALIA
 EN1057 – Y size X thickness R290

For Copper pipes with plastic sheath (Table Y) (Kemline) (cold water) (R250):
 KEMBLA MADE IN AUSTRALIA
 KEMLINE PLUS ® COPPER TUBE IS
 EN1057 – Y size X thickness HH

For Copper pipes with plastic sheath (Table Y) (Kemline) (cold water) (R290):
 KEMBLA MADE IN AUSTRALIA
 KEMLINE PLUS ® COPPER TUBE IS
 EN1057 – Y size X thickness R290

Expiry Date: 22 July 2025

This Authority hereby permits the use of the above pipes in fresh water plumbing systems and fresh water fire services systems subject to full adherence to Waterworks installation requirements.

A condition of this acceptance is that the pipes to be installed should be replicas of the samples as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the pipes installed fails to meet that of the approved samples or if the pipes are found to be unsuitable for use in the water supply systems mentioned above.

For the use of the pipes in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the pipes by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,



(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82] - without catalogue
 ME/MC] - with soft copy only