

## 水務署 Water Supplies Department

總部 Headquarters

香港灣仔告士打道七號人境事務大樓 48 樓

48/F, Immigration Tower, 7 Gloucester Road, Wan Chai, Hong Kong

本署檔號 Our ref. 來函檔號

Your ref.

(4) in WSD 3321/2020 T/J(1141/2020)

電話

Tel.

傳真 Fax.

: 2824 0578

26 November 2020

## Approval of "WINKLER" Sink Mixer (General Acceptance No. C20201060)

Your letters dated 25 August 2020 and 29 October 2020 refer.

Having considered the test report ref. BC-SUMMARY-2020-100 issued on 17 August 2020 by Castco Testing Centre Ltd., this Authority accepts that the fitting described below complies with, and its use when correctly installed does not contravene, the Waterworks Ordinance and Regulations.

Name of Manufacturer:

Winkler Limited

**Country of Origin:** 

the Mainland of China

Brand:

Winkler

**Details of Fitting:** 

1/2" Wall mounted sink mixer

Model:

WK-CL73

**Body Markings:** 

WINKLER

**Expiry Date:** 

10 August 2025





This Authority hereby permits the use of the above fitting in fresh water plumbing systems subject to full adherence to Waterworks installation requirements. In particular, you are required to draw your customers' attention to the following requirement-

"The cold water supply to the fitting shall be drawn from the same source that supplies the hot water apparatus so as to provide a balanced pressure and to obviate the risk of scalding in the event of a restriction or failure in the water supply."

A condition of this acceptance is that the fitting to be installed shall be replicas of the sample as certified by the testing agent mentioned above and without modifications. This acceptance may be withdrawn at any time if the standard of the fitting installed fails to meet that of the approved sample or if the fitting is found to be unsuitable for use in fresh water plumbing systems.

This acceptance is only applicable to the main body of the fitting, unless otherwise specified.

For the use of the fitting in any project, the General Acceptance Number of this letter must be quoted as a means of identification of acceptance of the fitting by this Authority.

Should you have any enquiries, please contact our Engineer Mr. Terry KUNG at tel. no. 3583 4086.

Yours faithfully,

(CHAN Chung-kun)

for Director of Water Supplies

Encl.

c.c. WSD 3321/1/82 ] - without catalogue ME/MC ] - with soft copy only



WK-CL73